

SECTION 08211– FLUSH WOOD DOORS
CONSTRUCTION STANDARD

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of the University of Texas at Austin for wood doors and panels; fire-rated and non-fire-rated; flush wood doors and panels with veneer facings.
- B. UT recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for UT projects.

1.02 National Wood Window and Door Association Standards (NWWDA)

1.03 Quality Control

- A. Interior core of door products: In no instance shall hollow core doors be allowed.

1.04 General Requirements

- A. Finish: Painted birch or stained book-matched wood veneer. Light color stain is preferred over a dark colored stain. Verify wood door appearance will either match or coordinate with woodwork used elsewhere throughout project.
- B. Warranty: Maximum warranty available will be required. Lifetime warranty preferred.
- C. Core: Use staved lumber core.
- D. Vertical Edges: Same species as face, lumber or veneer; sanded ease, no visible joints allowed. Fire rated, mineral core doors shall have minimum 1-3/8" thick solid edges or solid blocking at hinge and lockset locations.

PART 2: PRODUCTS

2.01 General

- A. Doors shall comply with NWWDA standards.
- B. Contractor shall not be permitted to install doors prior to building having conditioned air.

PART 3: EXECUTION – NOT USED

END OF STANDARD 08211