

**SECTION 08250 – ALUMINUM FRAME SYSTEM
CONSTRUCTION STANDARD**

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of the University of Texas at Austin for Aluminum Frame System.
- B. UT recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for UT projects.

1.02 Reference Standards

- A. ASTM E283, E330 and E331 for air and water infiltration requirements.

1.03 Quality Control

- A. Prior approval by the University of Texas at Austin project manager will be required for use of a mill finish product.
- B. Where utilizing in a remodel project, finish shall match existing.

1.04 General Requirements

- A. Factory pre-finish is required.
- B. UT-Austin has no color standard at this time.
- C. Verify thermal break provided at exterior locations.
- D. Window units are to be fixed, non-operable.
- E. Entrance and storefront systems shall accommodate building deflection without damage to system, components or seal.
- F. Provide minimum five years manufacturer's warranty.

PART 2: PRODUCTS – NOT USED

PART 3: EXECUTION – NOT USED

END OF STANDARD 08250