

SECTION 08800– WINDOW ASSEMBLIES
CONSTRUCTION STANDARD

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of the University of Texas at Austin for transparent and translucent glass for general and special purpose applications.
- B. UT recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for UT projects.

1.02 Quality Control

- A. In no instance will glass with a film coating be acceptable.
- B. Wire glass: Use of this type product is not preferred.

1.03 General Requirements

- A. Other: For exterior glazing, use of clear low E insulated glass is preferred. No reflective glass is to be used. If shading is necessary, it is preferred to use a light Gray color glass. Refer also to the “UT-Austin Campus Master Plan” for additional information.
- B. Manufacturers stamp is to be provided on all glass required by code to be heat tempered , heat strengthened or safety.
- C. Asbestos: In no instance will any product containing asbestos be acceptable for use.
- D. Lead: In no instance will any product containing lead be acceptable for use.

PART 2: PRODUCTS – NOT USED

PART 3: EXECUTION – NOT USED

END OF STANDARD 08800