

**SECTION 09511- ACOUSTICAL PANEL CEILING
CONSTRUCTION STANDARD**

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of the University of Texas at Austin for acoustical ceiling tiles and panels, perforated metal pan ceiling systems, and materials manufactured as finished acoustical ceiling surfaces.
- B. UT recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for UT projects.

1.02 Quality Control

- A. Patterns: Patterns shall be fissured and non-directional.
- B. Color: White
- C. Edge conditions: Panels shall be no less than 6" where adjacent to walls. Edge trim shall be "L" type.
- D. Fire resistant assemblies: Acoustical ceilings are not acceptable.
- E. Asbestos: In no instance will any product containing asbestos be acceptable for use.

1.03 General Requirements

- A. Over-stock: Provide 5% overage for attic stock.

PART 2: PRODUCTS

2.01 CEILING TILE

- A. General
 - 1. Panel: 24" x 24" x 5/8" lay-in acoustical ceiling tile No. 756 or 1811, fissured with standard DX grid as manufactured by Armstrong, or equal.

PART 3: EXECUTION - NOT USED

END OF STANDARD 09511