

**SECTION 10522– FIRE EXTINGUISHERS & CABINETS
CONSTRUCTION STANDARD**

PART 1: GENERAL

1.01 Scope of Standard

- A. This standard provides general guidance concerning the specific preferences of the University of Texas at Austin for fire extinguishers.
- B. UT recognizes that project conditions and requirements vary, thus precluding the absolute adherence to the items identified herein in all cases. However, unless there is adequate written justification, it is expected that these guidelines will govern the design and specifications for UT projects.

1.02 Reference Standards

- A. Reference Publications: NFPA 10, NFPA 10R, NFPA Fire Protection Handbook.

1.03 Quality Control

- A. Type: Cabinets for fire extinguishers shall be recess mounted. Cabinet exterior finish shall be brushed stainless steel.

PART 2: PRODUCTS – NOT USED

PART 3: EXECUTION – NOT USED

END OF STANDARD 10522